

Form



Pennsylvania
Department of
Environmental Protection

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF SAFE DRINKING WATER

PUBLIC NOTICE

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER FAILURE TO MONITOR

ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE
ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.

Monitoring Requirements Not Met for Borough of Chambersburg

Our water system violated one or more drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2025 we failed to monitor for the following contaminants and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, the required sampling frequency, how many samples we took, when samples should have been taken, and the date on which corrective action samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
TOC's	Quarterly	7	2025	2026

What happened? What was done? When will it be resolved?

The Borough of Chambersburg is required to take 2 sample for SOC's every quarter of each year. In 2025, the Borough has record of taking all 8 samples, however the accredited lab that the Borough uses did not receive our last sample. This was not caught by water plant staff in the proper amount of time resulting in a tier III violation. Per DEP recommendation the Borough will continue on the same sampling plan in the future.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information regarding this notice, please contact Travis Amsley at 717-261-6580.

Certified by:

Signature:

Date:

4-22-2026

Print Name and Title:

Tyler Seibert Water Plant Supervisor

As a representative of the Public Water system indicated above, I certify that public notification addressing the above violation was distributed to all customers in accordance with the delivery requirements outlined in Chapter 25 PA



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF SAFE DRINKING WATER

Code 109 Subchapter D of the Department of Environmental Protection (DEP's) regulations. The following methods of distribution were used: Online document posted to the Borough of Chambersburg website

PWS ID#: 7280005

Date distributed: 4/22/2026